

## EU DECLARATION OF CONFORMITY

This declaration of conformity is issued under the sole responsibility of the manufacturer

**Manufacturer:** ZPA Nová Paka, a.s., registered in the Commercial Register at the Regional Court in Hradec Králové, Section B, Inlet 644. **Registration No. 46504826**

**Seat:** Pražská 470, 509 39 Nová Paka, Czech Republic

**Name:** Servomotor controller NOTREP 21, 22, 25, 26

**Type:** 511 21, 22, 25, 26

**Basic data about product:**

Type of supply mains: 1 / N / PE AC 230 V 50 Hz

The product is an electrical equipment of protection class I according to EN 61140 ed. 2. designed for use in networks with the category of overvoltage in the installation II and pollution grade 2 according to EN 61010-1 ed. 2 and an internal power supply for the feedback circuit corresponds Art. 6.3 of this standard and complies with SELV and PELV. Controllers type 511 21 and 511 25 are plug-in units shipped separately. For controllers 511 22 and 511 26, the plug-in unit mounted in a casing of sheet steel covered with a lid. The driver in the cabinet has internal and external protection terminals, which are interconnected.

The driver is used for continuous control of the MODACT with motors of type J9A (16 W), J10A (25W), J11A (50 watts) electric motors ATAS Nachod Inc. Using this product defines the technical documentation for the product.

**The above described object of the declaration is in conformity with the relevant EU harmonization legislation:**

- Directive 2014/35/EU of the European Parliament and of the Council and standard: ČSN EN 61010-1:2011
- Directive 2014/30/EU of the European Parliament and of the Council and standards: ČSN EN 61000-6-2:2006, ČSN EN 61000-6-4:2007/A1:2011.


**and declares that**

properties of the product comply with requirements of basic safety principles and requirements of technical regulations and the product is, subjected to the conditions of correct installation, maintenance, operation and application, safe for the specified purpose; measures have been taken to ensure compliance of all marketed products with technical documentation and basic requirements of said Directives.

Last two digits of the year, in which the CE mark was placed on the product: 16

Signed for and on behalf of:

Nová Paka, April 20<sup>th</sup>, 2016

Name: Petr Fól  
Position: Quality Manager  
Signature: 



ZPA Nová Paka, a.s.  
Pražská 470  
509 39 Nová Paka  
IČO: 46 50 48 26