

EU DECLARATION OF CONFORMITY

This declaration of conformity is issued under the sole responsibility of the manufacturer

Manufacturer:

ZPA Nová Paka, a.s., registered in the Commercial Register at the

Regional Court in Hradec Králové, Section B, Inlet 644. Registration No.

46504826

Place:

Pražská 470, 509 01 Nová Paka, Czech Republic

Name:

Resistance temperature sensor without protective armature (jacketed)

with transmitter or Ex ia

Type:

212

Basic data about product:

Sensor with transmitter is designed for such temperature measurement, which is required for a short time temperature response, small size and flexibility of the sensor, high mechanical resistance to shock and vibration resistance, rapid changes in temperature, a large insulation resistance at normal ambient temperature and at high temperatures, good general corrosion resistance and high accuracy. Areas of application can be eg. Nuclear power, steam boilers, pressurized water reactors, aircraft engines, plastics processing, paper and food industry.

The Ex i sensors designed for environments with a risk of explosion of group II 1G Ex ia IIC T5 / T6 Ga. Sensors can be used in zone 0 when connected to an Ex i circuit. The product is marked in compliance with Article 1.0.5. of Directive 2014/34/EU. The product application is subjected to technical documentation of the product.

The above described object of the declaration is in conformity with the relevant EU harmonization legislation:

- Directive 2014/34/EU of European Parliament and Council and standards: EN IEC 60079-0:2018, EN 60079-11:2012

EU-Type Examination Certificate No. FTZÚ 21 ATEX 0007X.

Regular supervision over production quality assurance is realized by Notified Body EU No.1026 - FTZÚ Ostrava – Radvanice. Quality Assurance declaration No. FTZÚ 02 ATEX Q 026.

For sensors with transmitters, the assessment of conformity has been carried out pursuant to:

- Directive 2014/30/EU for transmitter type 420, manufacturer ZPA Nová Paka, a.s. pursuant to:
 - harmonised standard EN IEC 61326-1:2022,
 - standard CISPR11 (Group 1, Class A),
 - standards/level of rigorousness EN 61000-4-2/B, EN 61000-4-3/B, EN 61000-4-4/B, EN 61000-4-6/B

EU-212000-e-EN Page total: 2 Page: 1

- Directive 2014/30/EU and pursuant to standards for the individual types of transmitters for which EU declaration of conformity was issued by the manufacturer:

	Downwart to the	EU Declaration of	
Type	Pursuant to the standards	Conformity nr.	Issued by
	Standards	Comornity III.	
	EN 61326-1:2013		
	EN		
TH 100	55011:2009/A1:2010	A5E34145488A/004	
	EN 61000-6-2		
	EN 61000-6-		
	3:2007/A1:2011		
TH 200	EN 61326-1:2013		
	EN		G: A.C.
TH 300	55011:2009/A1:2010	A5E35131629A/004	Siemens AG
	EN 61000-6-2		
	EN 61000-6-		
	3:2007/A1:2011		
248 HA NA	EN 61326-1:2013	RMD 1134 Rev. B	EMERSON
644 HA NA	EN 61326-2-3:2013	RMD 1016 Rev. Y	Process Management
APAQ-HCF	EN 61326-1:2013	Issued 30.11.2018	INOR
APAQ-HRF		Issued 30.11.2018	
MESO-H		Issued 30.11.2018	Process AB
MINIPAQ-HLP		Issued 30.11.2018	
IPAQ-H		Issued 30.11.2018	n to n
C130	EN 61326-1:2013	Issued 30.09.2021	INOR
	EN 61326-2-3:2013		Process AB
C202	EN 61326-1:2013	Issued 14.01.2022	INOR
	EN 61326-2-3:2013		Process AB INOR
C330	EN 61326-1:2013	Issued 14.01.2022	Process AB
	EN 61326-2-3:2013 EN 61326-1:2013		INOR
C520, C520S		Issued 14.01.2022	Process AB
	EN 61326-3-1:2008 EN 61326-1:2013		INOR
C530	EN 61326-1:2013 EN 61326-2-3:2013	Issued 14.01.2022	Process AB
	EN 01320-2-3,2013		11000337115
TMT 182	EN 61326-1:2013	EC_00320_01.16	Endress+Hauser
	EN 61326-2-3:2013		Engress+nauser
		- 10-FD G 10-1	DD 1
5437A	EN 61326-1:2013	5437DoC_101	PR electronics A/S

and declares that

properties of the product comply with requirements of basic safety principles and requirements of technical regulations and the product is, subjected to the conditions of correct installation, maintenance, operation and application, safe for the specified purpose; measures have been taken to ensure compliance of all marketed products with technical documentation and basic requirements of said Directive.

Signed for and on behalf of:

Nová Paka, May 17th, 2022

Name: Position:

Petra Martincová Quality Manager

Signature:

ZPA Nová Paka, a.s. Pražská 470 509 01 Nová Paka IČ: 46 50 48 26 DIČ: CZ46504826